


GMRO
 $P_j = 10.0 \text{ kW}$
 $P_{\max} = K_j \sum P_i$
TT sistem




PP00-Y 5x16mm²

KPK

NVO 125/63A

prema uslovima ELD
 PP00 4x25mm² od noveTS

 URBANPROJEKT - PREDUZECE ZA KONSALTING, URBANIZAM, PROJEKTOVANJE I INZENJERING			
Odgovorni projektant Aleksander Ivanović, dipl. inž. el.	Paraf	Investitor Opština Pločica	
Projektovala Aleksander Ivanović, dipl. inž. el.		Naziv objekta i mesto gradnje PODZEMNA GARAŽA NA TRGU "13" JULI U PLOČICAMA	
Obradio Aleksander Ivanović, dipl. inž. el.		Naziv crteža JEDNOLINIJNA ŠEMA GMRO deo za merenje	
Director Andreja Andrić, dipl. inž. gr.		Datum 2008.	Razmera Broj 2